

CITY OF LAKEPORT

*Over 100 years of community,
pride, progress, and service*



CITY OF LAKEPORT

ADDENDUM NO. 1 2020 SEWER MAIN REPLACEMENT PROJECT Bid No. 20-04

Issued Date: May 4, 2020

The following revisions are hereby made to the above referenced project:

1. Attachment A: Clarifications, changes, and revised bid schedule
2. Attachment B: pre-bid meeting minutes, attendance and agenda for the meeting held 4/27/2020.
3. The bid date remains the same. However, due to the Covid-19 health concerns, the following procedures will be followed:
 - a. City Hall is closed but is still receiving mail and overnight shipments. There is reduced City staff. If you submit your bid via mail, please email Paul at paul@curren.ws and Olivia at ogrupp@cityoflakeport.com to alert us to your bid to assure that we can locate it prior to bid opening time.
 - b. Bids which will be submitted at City Hall prior to bid time will be received at the double doors from the Council Chambers to the west alleyway between 1:30 PM and 2 PM. No bids will be received after 2 PM.
 - c. Bidders may attend the bid opening in the Council Chambers. Chairs will be set up with appropriate social distancing in mind.
 - d. The bid opening will also be broadcast via a video conference link. If you desire to attend the bid opening using this method, please email Oliva Grupp at the above address and she will email back the link.

All questions regarding this project shall be transmitted in writing as indicated in the bid documents.

Please indicate receipt of this addendum on the proposal at the location indicated. Failure to do so may cause rejection of your bid.

Approved:

Paul Curren
City Engineer

Addendum No. 1-Attachment A

Item 1: Replace Bid Schedule with Attached.

Item 2: Add Section 700-5.1.12 BID ITEM A12 – 3 INCH TRENCH PAVING

A. Scope of Work

1. After completion of the work, cold plane 3 inch depth for trench paving to the width dimensions on the standard detail.
2. Place HMA and compact paving in a single lift.

B. Payment

1. Paid per each lineal foot measured along centerline of sewer pipe or lateral.
2. Includes all cost including cold planning, cleaning, disposal of grindings, tack coat. HMA materials and placement and finishing.

Item 3: Section 700-5.1.6.9 shall be changed from 30 lineal feet of trench plate to 100 feet of trench plate.

Item 4: The scope of work for Bid Item A11, Remove ACP Pipe, shall remain unchanged.

Item 5: Amend the third sentence in section 3-7.9 so that it reads as follows: AGENCY and its officers, agents and employees shall be named as additional insureds using ISO additional insureds endorsement form at least as broad as CG 20 10 11 85 or both CG 20 10, CG 20 26, CG 20 33, or CG 20 38; and CG 20 37 forms if later revisions used.

Addendum No. 1-Attachment A

**BID SCHEDULE (Continued)
2020 SEWER REPLACEMENT PROJECT
BID NO. 20-04
IN THE CITY OF LAKEPORT, CALIFORNIA**

The Contractor shall be responsible for calculating and providing unit prices for the bid schedule. The bid schedule shall include all costs for services, labor, materials, equipment, and installation associated with completing the work in place per the plans, specifications and details.

Schedule A - Ninth & N. Brush Street					
Item	Description	Unit	Qty	Unit Price	Extension
A1	Mobilization	LS	---	---	
A2	Traffic Control	LS	---	---	
A3	Construction Surveying	LS	---	---	
A4	Water Pollution Control Program	LS	--	--	
A5	Sheeting and Shoring	LS	---	---	
A6	R&R 6" PVC Sanitary Sewer Pipe	LF	867		
A7	Install New Manhole	EA	1		
A8	R&R Manhole	EA	4		
A9	New Rodding Inlet	EA	2		
A10	R&R 4" Sewer Lateral & Cleanout	EA	15		
A11	Remove and Dispose of ACP Pipe	LF	100		
A12	3 inch Trench Paving	LF	1017		
Schedule A Subtotal					
Schedule B - School Sewer Replacement					
Item	Description	Unit	Qty	Unit Price	Extension
B1	Mobilization	LS	---	---	
B2	Traffic Control	LS	---	---	
B3	Construction Surveying	LS	---	---	
B4	Water Pollution Control Program	LS	--	--	
B5	Sheeting and Shoring	LS	---	---	
B6	Install 10" Sanitary Sewer Pipe	LF	292		
B7	Install 8" Sanitary Sewer Pipe	LF	10		
B8	Install New Manhole over Existing Main	EA	1		
B9	Connect to Existing Manhole	EA	1		
Schedule B Subtotal					
Schedule C - Reconstruct Manhole at Giselman and Lakeshore					
Item	Description	Unit	Qty	Unit Price	Extension
C1	Mobilization	LS	---	---	
C2	Traffic Control	LS	---	---	
C3	Construction Surveying	LS	---	---	
C4	Water Pollution Control Program	LS	--	--	
C5	Sheeting and Shoring	LS	---	---	
C6	R&R Manhole	LS	---	---	
C7	6" Concrete Valley Gutter	SF	275		
Schedule C Subtotal					

Bid Schedule Total: \$ _____



MEETING MINUTES

Page 1 of 1

General Information **Pre-Bid**

Inspector	Vince Salsedo	Report Date	4/27/2020
Resident Engineer	Paul Curren	Report Day	Monday
Client Project Name	Sewer Main Replacement Project Bid No 20-04		

Contractor Information

General	TBD	Foreman	
Subcontractor		Foreman	
Subcontractor		Foreman	
Subcontractor		Foreman	

Meeting Information

Meeting Location	Start Time	Stop Time
Giselman St/Lakeshore Blvd intersection	10 am	

Attendees

Name	Representing	Telephone	Email
Paul Curren	City of Lakeport	707-695-5538	paul@curren.ws
Jim Kennedy	City of Lakeport	707-263-3578	jkennedy@cityoflakeport.com
Vince Salsedo	City of Lakeport	707-263-3578	vsalsedo@cityoflakeport.com
Travis Coleman	Coleman Envir Engineering Inc		travis@colemanconst.net

Meeting Minutes

1. The last day for questions is Friday May 1, 2020. An addendum will be issued with all questions Monday May 4, 2020.
2. There will be a pre-construction meeting prior to starting work.
3. The 9 th Street portion of work is the highest priority.
4. The City will investigate if it is acceptable to dispose of Transite pipe by leaving it in the ground and covering with sand.
5. The manholes at Giselman/Lakeshore and Lange St will need a gasket sealed type lid.
6. The contractor will need a bypass pump plan for the residence of 9 th St.
7. The City will accept grinding of trenches but the contractor will need to sawcut prior to final paving.
8. School location: there will be utilities to work around. Plan is to start the SSMH on Lange and work back to new SSMH at the basketball courts
9. The City will air test and video the pipes.

Resident Engineer

**City of Lakeport
Sewer Main Replacement Project
Bid 20-04
Pre-Bid Meeting
April 27, 2020
Agenda**

1. **Introductions**
City Staff
 - Paul Curren, City Engineer
 - Douglas Grider, Public Works Director
 - Paul Harris, Utilities Superintendent
 - Jim Kennedy, Public Works Superintendent
 - Olivia Grupp, Contract Administrator
 - Vince Salsedo, Inspector
2. **Project Scope Overview**
 - 40 Working Days**Working Hours**
 - 7 am to 6 pm
3. **Administration Considerations**
 - Notice (and approval) of Subcontractors to be Used (Provide contact information for foreman and also scope of work)
 - Weekly Prevailing Wage Certified Payrolls from Prime and Subs, must be registered as Public Works Contractor
 - Addenda will be issued with Meeting Notes, corrections, etc.
4. **Construction Scheduling & Phasing**
 - Permits
 - Weather
 - Payment
 - Limits on Work Area
 - Utility Coordination
 - Questions/Clarifications
 - Meetings
 - Schedule
 - Inspections
5. **Review Plans and Scope of Work**

Section B1.05 However, the soils at the Lakeshore and Giselman site are saturated and unstable below the surface and above the required excavation depth. The contractor is cautioned that sheeting and shoring in this area will require full sheeting and support for the entire depth of excavation. The bottom of the excavation can be expected to be unstable.

Section 700- 4 Order of Work
School Site First
Manhole at Lakeshore 2nd

Ninth Street Area Last

Section 5.1.11 – Bid Item A11 - Contractor to dispose of ACP pipe

Trench Paving Requirements:

On School site and Giselman/Lakeshore, restore final paving per standard detail requirements. Paving included in pipe price.

On Ninth and related streets, sand slurry to surface. City will follow to pave entire street.

Section 703-2: The manhole frames and lids at Lange and Lakeshore shall be D&L model No. E-1928 from DL Foundry & Supply or equal approved prior to bid.

6. Site Walk & Questions