

# CITY OF LAKEPORT

*Over 100 years of community, pride,  
progress, and service*



## ADDENDUM NO. 1 SOUTH MAIN STREET SIDEWALK PROJECT Bid No. 24-03

Issue Date: March 8, 2024

### **The following revisions are hereby made to the above referenced project:**

1. The bid date remains the same.
2. Revised bid schedule is attached with changes noted in red. (1 page)

### **Questions and clarifications:**

1. Q. Who pays for compaction testing if required?  
A. *Contractor. However, none is anticipated. Compaction by observation of City representative.*
2. Q. If field office or laboratory required for this project?  
A. *Not required*
3. Q. Will the city provide a staging area for this project? If so where?  
A. *Yes, the lot directly north of the new park is available. It is known as Dutch Harbor at 910 N Main St*
4. Q. Location 1 and a portion of location 2 either has no gutter on the curb or it's paved over. Does the new curb in these areas have a gutter? If so does it get paved over?  
A. *New curb and gutter at both locations to match existing width. Gutter does not get paved over.*
5. Q. The plans call for removing 2 stumps at Area 4. The trees are still there. Is someone else removing the 2 trees?  
A. *The trees will be removed by others prior to the project start.*
6. Q. What is the anticipated start date of this project?  
A. *May 28, 2024 is the anticipated start date.*
7. Q. In area 7 the curb and gutter to be installed will be new curb & gutter not replacement. On City Standard 205 it says that all new curb and gutter non-residential has a 24" wide gutter. The drawings have a total width of the new curb & 1.5 feet wide. What is the width of the new gutter pan to be installed in this area?

*A. Match existing width of gutter.*

8. Q. We believe the quantity for item 11-6" Paving is over 25% off. Can this be checked?

*A. The corrected quantity is 3,038. See revised bid schedule attached.*

9. Q. Does the City provide a dumpsite for the surplus dirt and tree stumps?

*A. Clean dirt and the 2 stumps can be disposed of at the City's Recycle Yard off Hwy 175. All other material will be the contractor's responsibility.*

All questions regarding this project shall be transmitted in writing as indicated in the bid documents.

Please indicate receipt of this addendum on the proposal at the location indicated. Failure to do so may cause rejection of your bid. There are 3 total pages in this addendum.

Approved:

A handwritten signature in black ink, appearing to read "Paul R. Curren". The signature is fluid and cursive, with the first name "Paul" being the most prominent.

Paul Curren City Engineer

**BID SCHEDULE (Continued)**

**SOUTH MAIN STREET SIDEWALK PROJECT  
BID NO. 24-03  
IN THE CITY OF LAKEPORT, CALIFORNIA**

The Contractor shall be responsible for calculating and providing unit prices for the bid schedule. The bid schedule shall include all costs for services, labor, materials, equipment, and installation associated with completing the work in place per the plans, specifications and details.

SOUTH MAIN STREET SIDEWALK PROJECT					
BID NO. 24-03					
Bid Schedule-Addendum 1					
Item	Description	Unit	Quantity	Unit Price	Extension
1	Mobilization	LS	---		
2	Traffic & Pedestrian Control	LS	---		
3	WPCP	LS	---		
4	4" R&R Sidewalk	SF	2452		
5	R&R Commercial Driveway	SF	783		
6	R&R Cross Gutter	SF	217		
7	R&R Curb and Gutter	LF	401		
8	Truncated Domes	SF	194		
9	Curb Behind Sidewalk	LF	273		
10	Excavation (F)	CY	165		
11	6" Miscellaneous Paving	SF	3038		
12	2" Miscellaneous Paving	SF	556		
13	Remove Stumps	EA	2		
14	HMA Dike (Type E)	LF	28		
15	Install Stop Sign and Post	EA	1		
16	Ramp, Landing & Handrail	LS	1		
Total					

**Bid Schedule Total: \$** \_\_\_\_\_

**Bid Schedule Total (in words):**

\_\_\_\_\_

\_\_\_\_\_

—

\_\_\_\_\_  
(Company Name of Bidder)

\_\_\_\_\_  
(Date)